



Notes:

1. Position air valve and stop valve behind sidewalk.
2. Minimum depth of cover to top of air valve body is 30".
3. Use elbow fittings where bending of 1-inch poly pipe is not possible due to water main depth.
4. Meter box and lid shall be traffic rated.

P:\Engr & CAD\STANDARD DWGS - ALL YEARS\Std Dwgs 2014\Waterline Air Valve 16.dwg

dwc 3-00
DRR

AIR VALVE

PAGE NO:

16