



NOTES:

1. Entry width shall be as required, with a 50 ft. minimum length. Entry length may be reduced to 25 ft. minimum for sites containing less than one acre of exposed soil. (See Note 2)
2. Install full depth of rock for the full width of the entrance: 15' Min.
3. Smaller crushed rock such as base course with minimal fines may be used on projects less than 1 acre in size.
4. Separation geotextile shall be placed under spalls on projects 1 acre and greater in size.

P:\Engr & CAD\STANDARD DWGS - ALL YEARS\Std Dwgs 2014\Construction Entrance 35.dwg

CONSTRUCTION ENTRANCE

PAGE NO:
35